



The Trusted Name In Home Comfort

Certificate of Completion

Duct Sealing performed for
9105 Edinburg Lane

Overall Sealing Results


When we arrived, your ducts had:
937 CFM of leakage,
equivalent to a
178 square inch hole

After we finished, your ducts had:
54 CFM of leakage,
equivalent to a
10 square inch hole

**Results in a
94% Reduction
in duct leakage**

Note: duct leakage results are calculated in cubic feet per minute (CFM) measured at a standard reference pressure of 25 pa (.10 inches of water)

Aeroseal Sealing Profile



Your heating and cooling capacity improvement for duct sealing is 52% based upon measured leakage reduction and original register flow.

AEROSEAL.

Certified Duct Diagnostics & Sealing

Aeroseal equipment serial number: 969